

April 13, 2009

TUF-TITE  
TED MEYERS  
1200 FLEX CT  
LAKE ZURICH IL 60047-1570

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER  
Manufacturer: TUF-TITE  
Product Name: EFFLUENT FILTER  
Model Number(s): EF-4  
[MAX. DWF 800 GPD]  
Product File No: 20090152

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in the outlet tee of sewage treatment compartment or tank having a flow rate of no greater than 800 GPD.
- A 1.25-in. hole must be drilled in the top of the filter within an inch of the slots provide for venting prior to being installed in the outlet tee.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- MAINTENANCE: The manufacturer recommends this unit be cleaned every time the tank is pumped or at least once every three years.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #####.

This product type category has been changed to better reflect its use; it was previously approved as STA- sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

TUF-TITE  
Page 2  
April 13, 2009

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@WI.GOV